



Final 2016-2017 UDRH Inputs: Addendum to Massachusetts Multifamily High Rise Baseline Study

March 8, 2017

SUBMITTED TO:
The Electric and Gas Program Administrators of
Massachusetts

SUBMITTED BY:
NMR Group, Inc. & Dorothy Conant

NMR
Group, Inc.

Table of Contents

FINAL UDRH INPUTS1

Tables

TABLE 1: RESIDENTIAL AND COMMON AREA LIGHTING2
TABLE 2: RESIDENTIAL/COMMON AREA HEATING SYSTEMS4
TABLE 3: RESIDENTIAL/COMMON AREA COOLING SYSTEMS.....5
TABLE 4: IN-UNIT WATER HEATING.....6
TABLE 5: WALL INSULATION7
TABLE 6: ROOF INSULATION7
TABLE 7: FENESTRATION EFFICIENCY8
TABLE 8: SHOWERHEADS AND FAUCET FLOW RATES.....9
TABLE 9: INFILTRATION AND VENTILATION 10

UDRH

Final UDRH Inputs

The evaluation team conducted two conference calls to review the preliminary baseline findings provided in the draft Multifamily High Rise Baseline Study report.¹ The group participating in this review included Program Administrators (PAs), Energy Efficiency Advisory Council (EEAC) Consultants, and representatives from the program implementation contractor (ICF). Together, this group reviewed and developed a final set of User Defined Reference Home (UDRH) inputs that incorporates baseline study findings along with additional information based on experience administering the Multifamily High Rise (MFHR) program. This addendum documents the UDRH inputs that will be used when calculating savings retrospectively for 2016 program projects and prospectively for 2017 program projects. The tables below detail the following information:

- The current baseline inputs
- Updated inputs that will be used retrospectively to re-run savings for the 2016 program year (PY2016)
- Updated inputs that will be used prospectively to calculate savings for the 2017 program year (PY2017)
- Sources for new baseline inputs

Table 1 presents the new baseline inputs for residential and common area lighting. For in-unit residential lighting, the working group agreed to use a value 0.75 watts per square foot; this value will be used both retrospectively and prospectively. The in-unit residential lighting value was selected based on reviewing the current study results and considering the results of other lighting studies conducted by the PAs.

For common area lighting, the working group agreed to use different values retrospectively and prospectively. Retrospectively, for use in re-running the 2016 program year savings, the working group agreed to reduce the 2012 IECC lighting requirements by 27%. This decision was made based on the results of the most recent commercial code compliance baseline study², which found that lighting power densities are frequently lower (more energy efficient) than code requirements in commercial and industrial applications. Prospectively, for use in the 2017 program year, the group agreed to apply a 10% reduction to the 2015 IECC lighting tables. This decision has already been applied to other commercial and industrial lighting programs.

¹ NMR Group, Dorothy Conant, and DNV-GL. *Massachusetts Multifamily High Rise Baseline Study-DRAFT REPORT*. Submitted to the Massachusetts Electric and Gas Program Administrators. January 13, 2017.

² <http://ma-eeac.org/wordpress/wp-content/uploads/Commercial-New-Construction-Energy-Code-Compliance-Follow-up-Study.pdf>

Table 1: Residential and Common Area Lighting

UDRH Input	Current Input	Retrospective Baseline		Prospective Baseline	
		Inputs for PY2016	Source	Inputs for PY2017	Source
Residential Lighting Power Density (LPD)	1.1 W/SF	0.75 W/SF	Working group decision	0.75 W/SF	Working group decision
Lobby LPD	0.9 W/SF	0.80 W/SF (0.73* 1.1)	Working group decision; 27% reduction to 2012 IECC Table C405.5.2(2) Lobby	0.81 W/SF (.90*0.9)	Working group decision; 10% reduction to 2015 IECC Table C405.4.2(2) Lobby: Otherwise
Office LPD	1.11 W/SF	0.80 W/SF (0.73* 1.1)	Working group decision; 27% reduction to 2012 IECC Table C405.5.2(2) Office-enclosed	0.99 W/SF (.90*1.1)	Working group decision; 10% reduction to 2015 IECC Table C405.4.2(2) Office: Enclosed
Fitness LPD	0.72 W/SF	0.66 W/SF (0.73*0.9)	Working group decision; 27% reduction to 2012 IECC Table C405.5.2(2) Fitness center	0.65 W/SF (.90*0.72)	Working group decision; 10% reduction to 2015 IECC Table C405.4.2(2) Fitness Center: In an exercise area
Recreation LPD	0.73 W/SF	0.58 W/SF (0.73* 0.8)	Working group decision; 27% reduction to 2012 IECC Table C405.5.2(2) Lounge/recreation	0.66 W/SF (.90*0.73)	Working group decision; 10% reduction to 2015 IECC Table C405.4.2(2) Lounge/Breakroom: Otherwise
Storage LPD	0.63 W/SF	0.58 W/SF (0.73* 0.8)	Working group decision; 27% reduction to 2012 IECC Table C405.5.2(2) Storage	0.57 W/SF (.90*0.63)	Working group decision; 10% reduction to 2015 IECC Table C405.4.2(2) Storage
Corridor LPD	0.66 W/SF	0.51 W/SF (0.73*0.7)	Working group decision; 27% reduction to 2012 IECC Table C405.5.2(1) Multifamily	0.59 W/SF (.90*0.66)	Working group decision; 10% reduction to 2015 IECC Table C405.4.2(2) Corridor: Otherwise

Table 2 presents the new baseline inputs for residential and common area heating systems. The bullets below detail the assumptions associated with each heating system measure.

- **Whole building central boiler:** Natural gas hot water boilers that are less than 300,000 Btu/h are subject to the current federal standard of 82%. Larger boilers ($\geq 300,000$ Btu/h) are subject to a baseline input of 85% Thermal Efficiency; this value comes from the gas boiler market characterization study that is not yet complete.
- **Furnace with central A/C:** Furnaces that are less than 225,000 Btu/h are subject to a pre-existing baseline of 85% AFUE; this value was previously agreed to by the PAs and EEAC for other programs. Larger furnaces ($\geq 225,000$ Btu/h) are subject to the current federal standard of 80% Thermal Efficiency.
- **Ductless mini-split heat pump:** Ductless mini-splits are subject to a new baseline value of 8.2 HSPF; this value comes from the recently completed ductless mini-split heat pump impact evaluation.³ The new baseline values for ductless mini-split heat pumps were confirmed with the PAs.
- **Water source heat pumps, ground source heat pumps, and variable refrigerant flow (VRF) systems:** Retrospectively, the baseline values for these systems are based on ASHRAE 90.1-2010 and the 2012 IECC. These values will be used to re-run program savings for the 2016 program year. Prospectively, for the 2017 program year, the baseline values for these systems are based on ASHRAE 90.1-2013 and the 2015 IECC.

³ <http://ma-eeac.org/wordpress/wp-content/uploads/Ductless-Mini-Split-Heat-Pump-Impact-Evaluation.pdf>

Table 2: Residential/Common Area Heating Systems

UDRH Inputs	Current Inputs	Retrospective Baseline		Prospective Baseline	
		Inputs for PY2016	Source	Inputs for PY2017	Source
Whole Building Central Boiler	80% Thermal Efficiency	<300,000 Btu/h 82% AFUE ≥300,000 Btu/h 85% Thermal Efficiency	<300,000 Btu/h: current federal standard* ≥300,000 Btu/h: pre-existing baseline from gas boiler market characterization study	<300,000 Btu/h 82% AFUE ≥300,000 Btu/h 85% Thermal Efficiency	<300,000 Btu/h: current federal standard* ≥300,000 Btu/h: pre-existing baseline from gas boiler market characterization study
Furnace with Central A/C	80% Thermal Efficiency	<225,000 Btu/h, 85% AFUE ≥225,000 Btu/h, 80% Thermal Efficiency	<225,000 Btu/h: pre-existing baseline from other programs ≥225,000 Btu/h: 2012 IECC Table 403.2.3(4)	<225,000 Btu/h, 85% AFUE ≥ 225,000 Btu/h, 80% Thermal Efficiency	<225,000 Btu/h: pre-existing baseline from other programs ≥225,000 Btu/h: ASHRAE 90.1-2013 Table 6.8.1-5
Ductless Mini-Split Heat Pumps	7.7 HSPF	8.2 HSPF	Pre-existing baseline from other programs; based on mini-split heat pump impact evaluation	8.2 HSPF	Pre-existing baseline from other programs; based on mini-split heat pump impact evaluation
Water Source Heat Pumps	4.2 COP	4.2 COP	ASHRAE 90.1-2010 Table 6.8.1B, Water to air, water loop	4.3 COP	ASHRAE 90.1-2013 Table 6.8.1-2, Water to air, water loop
Ground Source Heat Pumps	3.1 COP	3.1 COP	ASHRAE 90.1-2010 Table 6.8.1B, Brine to air, ground loop	3.2 COP	ASHRAE 90.1-2013 Table 6.8.1-2, Brine to air, ground loop
VRF-Air-Cooled	2.05 COP	2.05 COP	ASHRAE 90.1-2010 Table 6.8.1J, ≥135,000 Btu/h	2.05 COP	ASHRAE 90.1-2013 Table 6.8.1-10, ≥135,000 Btu/h
VRF-Air-Cooled with Heat Recovery	2.05 COP	2.05 COP	ASHRAE 90.1-2010 Table 6.8.1J, ≥135,000 Btu/h	2.05 COP	ASHRAE 90.1-2013 Table 6.8.1-10, ≥135,000 Btu/h

*http://www.ecfr.gov/cgi-bin/text-idx?SID=80dfa785ea350ebee184bb0ae03e7f0&mc=true&node=se10.3.430_132&rgn=div8

**FINAL 2016-2017 UDRH INPUTS:
MASSACHUSETTS MULTIFAMILY HIGH RISE BASELINE STUDY**

Table 3 presents the new baseline inputs for residential and common area cooling systems. Retrospectively, all inputs other than ductless mini-splits, are based on ASHRAE 90.1-2010 and the 2012 IECC requirements. Prospectively, all inputs other than ductless mini-splits are based on ASHRAE 90.1-2013 and the 2015 IECC requirements. The ductless mini-split values, both retrospective and prospective, were agreed upon by the working group and are based on the recent ductless mini-split heat pump impact evaluation that was previously mentioned.

Table 3: Residential/Common Area Cooling Systems

UDRH Inputs	Current Inputs	Retrospective Baseline		Prospective Baseline	
		Inputs for PY2016	Source	Inputs for PY2017	Source
Furnace with Central A/C	13.0 SEER	13.0 SEER	Current federal standard*	13.0 SEER	Current federal standard*
Hydronic Heating with Central A/C	13.0 SEER	13.0 SEER	Current federal standard*	13.0 SEER	Current federal standard*
Ductless Mini-Split Heat Pumps	13.0 SEER	14.5 SEER and 12.0 EER	Pre-existing baseline from other programs; based on mini-split heat pump impact evaluation	14.5 SEER and 12.0 EER	Pre-existing baseline from other programs; based on mini-split heat pump impact evaluation
Water Source Heat Pumps	12.0 EER	12.0 EER	ASHRAE 90.1-2010 Table 6.8.1B, Water to air, water loop	13.0 EER	ASHRAE 90.1-2013 Table 6.8.1-2, Water to air, water loop
Ground Source Heat Pumps	13.4 EER	13.4 EER	ASHRAE 90.1-2010 Table 6.8.1B, Brine to air, ground loop	14.1 EER	ASHRAE 90.1-2013 Table 6.8.1-2, Brine to air, ground loop
VRF-Air-Cooled	10.6 EER	10.6 EER	ASHRAE 90.1-2010 Table 6.8.1J, ≥135,000 Btu/h	10.6 EER	ASHRAE 90.1-2013 Table 6.8.1-10, ≥135,000 Btu/h
VRF-Air-Cooled with Heat Recovery	10.4 EER	10.4 EER	ASHRAE 90.1-2010 Table 6.8.1J, ≥135,000 Btu/h	10.4 EER	ASHRAE 90.1-2013 Table 6.8.1-10, ≥135,000 Btu/h
Hydronic Baseboard with Through-Wall A/C	12.0 SEER	12.0 SEER	ASHRAE 90.1-2010 Table 6.8.1A	12.0 SEER	ASHRAE 90.1-2013 Table 6.8.1-2, Through the wall, air cooled

*http://www.ecfr.gov/cgi-bin/text-idx?SID=a9921a66f2b4f66a32ec851916b7b9d9&mc=true&node=se10.3.430_132&rgn=div8

Table 4 presents the new baseline inputs for in-unit water heating technologies. Retrospectively, the program will use the energy factors specified in the commercial section of the 2012 IECC. These are federal standards that were in place prior to April 16, 2015. For the 2017 program year, the program will use new federal standards that went into place on April 16, 2015 as the baseline inputs for the program. It is likely that buildings enrolled in the 2016 program year installed water heaters that were manufactured before the new federal efficiency standards went into place. Therefore, the Team feels it is reasonable to use the previous federal standards when re-running savings for the 2016 program year.

Table 4: In-Unit Water Heating

UDRH Inputs	Current Inputs	Retrospective Baseline		Prospective Baseline	
		Inputs for PY2016	Source	Inputs for PY2017	Source
In-Unit Natural Gas Storage Water Heater	0.67 Thermal Efficiency	0.67-0.0019V EF	2012 IECC Table C404.2	≤55 gallons, 0.675-.0015V EF; >55 gallons, 0.8012-0.00078V EF	Effective federal standard on or after April 16, 2015*
In-Unit Natural Gas On-Demand Water Heater	0.62 Thermal Efficiency	0.62-0.0019V EF	2012 IECC Table C404.2	0.82-0.0019V EF	Effective federal standard on or after April 16, 2015*
In-Unit Electric Storage Water Heater	0.97-0.00132V EF	0.97-.00132V EF	2012 IECC Table C404.2	≤55 gallons, 0.960-.0003V EF; >55 gallons, 2.057-0.00113V EF	Effective federal standard on or after April 16, 2015*
In-Unit Electric On-Demand Water Heater	0.97-0.00132V EF	0.97-.00132V EF	2012 IECC Table C404.2	0.93-0.00132V EF	Effective federal standard on or after April 16, 2015*
In-Unit Electric Heat Pump Water Heater	0.97-0.00132V EF	0.93-.00132V EF	2012 IECC Table C404.2	≤55 gallons, 0.960-.0003V EF; >55 gallons, 2.057-0.00113V EF	Effective federal standard on or after April 16, 2015*

* <http://buildingsdatabook.eere.energy.gov/TableView.aspx?table=7.5.3>

Table 5 and Table 6 present the new baseline inputs for wall and roof insulation. Once again, the retrospective baseline values are based on ASHRAE 90.1-2010 and the 2012 IECC while the prospective values are based on ASHRAE 90.1-2013 and the 2015 IECC. The only difference between the two codes is for flat roof insulation that is entirely above the roof deck. The on-site results for these measures were reviewed as part of this process, but the working group ultimately decided to use code as the baseline given the small sample sizes associated with this study.

Table 5: Wall Insulation

UDRH Inputs	Current Inputs	Retrospective Baseline		Prospective Baseline	
		Inputs for PY2016	Source	Inputs for PY2017	Source
Mass	R-13.3 c.i.	R-13.3 c.i.	2012 IECC Table C402.2	R-13.3 c.i.	2015 IECC Table C402.1.3
Wood Stud	R-13.0 + R-7.5 c.i.	R-13 + R-7.5 c.i. or R-20 + R-3.8 c.i.	2012 IECC Table C402.2	R-13 + R-7.5 c.i. or R-20 + R-3.8 c.i.	2015 IECC Table C402.1.3
Steel Frame	R-13.0 + R-7.5 c.i.	R-13 + R-7.5 c.i.	2012 IECC Table C402.2	R-13 + R-7.5 c.i.	2015 IECC Table C402.1.3

Table 6: Roof Insulation

UDRH Inputs	Current Inputs	Retrospective Baseline		Prospective Baseline	
		Inputs for PY2016	Source	Inputs for PY2017	Source
Flat Roof	R-20.0 c.i.	R-25 c.i.	2012 IECC Table C402.2	R-30 c.i.	2015 IECC Table C402.1.3
Attic	R-38.0	R-49	2012 IECC Table C402.2	R-49	2015 IECC Table C402.1.3

Table 7 presents the new baseline inputs for fenestration. There are no differences between the 2012 IECC and 2015 IECC and both codes cover fixed fenestration, operable fenestration, and entrance doors.

Table 7: Fenestration Efficiency

UDRH Inputs	Current Inputs	Retrospective Baseline		Prospective Baseline	
		Inputs for PY2016	Source	Inputs for PY2017	Source
Fenestration U-Factor	U-0.35	Fixed fenestration U-0.38	2012 IECC Table C402.3	Fixed fenestration U-0.38	2015 IECC Table C402.4
		Operable fenestration U-0.45		Operable fenestration U-0.45	
		Entrance Doors U-0.77		Entrance Doors U-0.77	

Table 8 presents the new baseline inputs for showerhead and faucet flow rates. The baseline study findings suggest that the current baseline inputs are not reflective of the market. The working group was not comfortable directly applying the study results as the baseline due to the makeup of the study sample being disproportionately weighted towards the largest multi-family projects. As a result, the working group agreed to use values recommended by ICF based on their industry experience. The same values will be used retrospectively and prospectively for showerhead and faucet flow rates.

Table 8: Showerheads and Faucet Flow Rates

UDRH Inputs	Current Inputs	Retrospective Baseline		Prospective Baseline	
		Inputs for PY2016	Source	Inputs for PY2017	Source
Showerheads	2.5 GPM	2.2 GPM	Working group decision	2.2 GPM	Working group decision
Lavatory Faucets	2.2 GPM	2.0 GPM	Working group decision	2.0 GPM	Working group decision
Kitchen Faucets	2.2 GPM	2.2 GPM	Working group decision	2.2 GPM	Working group decision

Table 9 presents the new baseline inputs for whole building infiltration and ventilation. The new infiltration rate baseline value is specified in both ASHRAE 90.1-2010 and ASHRAE 90.1-2013. Ventilation was not discussed by the working group but the evaluation team recommends that the program continue to use the current baseline assumption that no ERV or HRV units are installed for corridor ventilation supply air.

Table 9: Infiltration and Ventilation

UDRH Inputs	Current Inputs	Retrospective Baseline		Prospective Baseline	
		Inputs for PY2016	Source	Inputs for PY2017	Source
Whole Building Infiltration Rate	0.35 CFM75/SF of exterior surface area	0.40 CFM75/SF of exterior surface area	ASHRAE 90.1-2010 Section 5.4.3.1.3	0.40 CFM75/SF of exterior surface area	ASHRAE 90.1-2013 Table C3.5.5.3
ERV/HRV	None installed on corridor ventilations supply air	None installed on corridor ventilations supply air	Evaluator Recommendation	None installed on corridor ventilations supply air	Evaluation Recommendation